

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 153/UJS/DLWQTML/2023-24

Dated: 26/04/2024

It is certified that an inspection team headed by Dr. Vikash Khandari, Chief Chemist

(Name of Officers with designation) from District Lab, U.S. (PHED), Dehradun

inspected the Shri Ram Janki Public School, Chandabani Chola, Mohabbuwala, Dehradun

(Name & Address of the school) on 24/04/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 153/UJS/DLWQTML/23-24 dated 26/04/2024

of District Lab, Dehradun (PHED Lab) certified that the

Shri Ram Janki Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till as per rules

Signature with Seal: 

Name

Dr. Vikash Khandari

Designation

Chief Chemist

Name & Address of the Office / Department: U.S. Dehradun

To

Shri Ram Janki Public School
Chandabani Chola, Mohabbuwala, Dehradun
(Name & Address of the Institution)

Authorized Signature

DLWQTML

Uttarakhand Jal Sansthan

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Principal

65 | SHRI RAM JANKI PUBLIC SCHOOL
Dehradun (Uttarakhand)



Chairperson

SHRI RAM JANKI PUBLIC SCHOOL
Dehradun (Uttarakhand)



**District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun**

Test Report ID: 153/UJS/DLWQTML/2023-24

Dated: 26/04/2024

TEST REPORT

Name and Address of Organization/ Customer		Shri Ram Janki Public School, Chandarbani Choila, Mohabbewala, Dehradun			
Product Description		Drinking Water	Sample Description	One Water Sample Submitted to Shri Ram Janki Public School, Dehradun	
Reference Sample Identification:		DLWQTML/UJS/2024-153		Date of Start of Analysis: 24/04/2024	
Date and Time of Sample Received: 24/04/2024 & 02:30 PM		Sample Collected by:		Date of End of Analysis: 26/04/2024	
				Customer	

SN	Water Quality Parameters Under Chemical Scope	Results	Acceptable Limit As per IS 10500:2012	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH at 25°C	7.36	6.5 to 8.5	No Relaxation	IS 3025 (Part 11) 2022, Electrometric method
2.	Total Dissolved Solids (TDS), mg/L, Max	228	500	2000	IS 3025 (Part 16), 2023 Gravimetric Method
3.	Turbidity, NTU, Max	Less than 0.02	1	5	IS 3025 (Part 10), 2023 Nephelometric Method
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	126	200	600	IS 3025 (Part 23), 2023 Titrimetric Method
5.	Total Hardness (as CaCO ₃), mg/L, Max	140	200	600	IS 3025 (Part 21), 2009 RA:2019, EDTA Titrimetric Method
6.	Calcium as Ca, mg/l	28	75	200	IS 3025 (Part 40), 1991 RA:2019, EDTA Titrimetric Method
7.	Chloride, mg/L, Max	12.74	250	1000	IS 3025 (Part 32), 2019 Argentometric Method
8.	Magnesium as Mg, mg/l	17.01	30	100	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)
9.	Colour, Hazen, Max	Less than 01	5	15	IS 3025 (Part 4): 2021 Platinum Cobalt (Visual Comparison)
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2018

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

[Signature]
Principal
SHRI RAM JANKI PUBLIC SCHOOL
Dehradun (Uttarakhand)

[Signature]
Chairperson
SHRI RAM JANKI PUBLIC SCHOOL
Dehradun (Uttarakhand)

Reviewed and Authorized By
[Signature]
Dr. Vikash Kandari
Technical Manager, Lab
Authorized Signature
DLWQTML
Uttarakhand Jal Sansthan